


T E S T C E R T I F I C A T E


BT-24-06-12-01

- Product:** Thermally modified Pinus radiata - Vulcan
Origin of timber: New Zealand
Treatment: Abodo Vulcan TM Schedule
- Producer/
Supplier:** Abodo Wood Limited
62 Ascot Road, Mangere, 2022 Auckland, New Zealand
- Order:** Durability testing against wood-destroying basidiomycete fungi after water leaching and durability classification (EN 113-2:2020/ EN 84:2020/ EN 350:2016)
- Test report:** 2223061/2 dated 30 May 2024
- Test details:** Each 30 specimens were tested using three test fungi (*Coniophora puteana*, *Rhodonia placenta* and *Trametes (Coriolus) versicolor*).
- Test results:** The product is assigned to DC 1 (durability class 1 "very durable"). The classification comprises five durability classes from DC 1 "very durable" to DC 5 "not durable".

Place, date of issue: Dresden, 12 June 2024



Head of laboratory



Engineer in charge